

Confirmation

LEED

On 31 October 2017, Eurofins Product Testing A/S received a sample of a Protection product with the product name:

PROTECTGUARD Em Premium

supplied by

Guard Industrie SAS

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, CDPH, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00384903_H_EN_rev1 and 392-2017-00389203_XG_EN).

The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of CARB SCM 2007
- the requirements of SCAQMD rule 1113 (2011)

8 December 2017



Maria Pelle Madsen
Analytical Chemist



Janne Rothmann Norup
Analytical Service Manager